

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

ESTE INFORME CONTIENE INFORMACIÓN IMPORTANTE ACERCA DE SU AGUA POTABLE. HAGA QUE ALGUIEN LO TRADUZCA PARA USTED, O HABLE CON ALGUIEN QUE LO ENTIENDA.

Monitoring Requirements Not Met for Individual Filter Effluent Turbidity

Our water system violated several drinking water standards over the past year. Even though these were not emergencies, as our customers, you have a right to know what happened and what we did to correct these situations.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 11/2014-12/2014 we monitored, but failed to continuously record individual filter effluent turbidity levels _____ and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for during the last year, how often we are supposed to sample for individual filter turbidity _____ and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When all samples should have been taken	When samples were or will be taken
Individual Filter Effluent Turbidity	Continuous	-	15 Minutes	Samples were taken but not recorded

What happened? What was done?

A new computer system was installed during our plant upgrade and the Turbidity recording system was not added. This was fixed immediately after it was caught.

For more information, please contact Tarentum Water Plant, 618 5th Ave. _____ at 724-224-9688 _____.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you as a resident of Tarentum Boro _____.

PWS ID#: 5020055 _____

Date distributed: 10-30-15 _____