

Tarentum Water Plant June 2019 Report

Amount of water processed.....29.05

Overtime Hours.....40 hrs.

All June reports and testing have been completed and submitted

Maintenance performed not including dily routine testing, sampling, and maintenance

Cryptosporidium/Ecoli. Smpling

Pump House Project started. Approx. one third complete

Repaired #2 Claratrac sludge remover

Cleaned #2 basin

Ordered 5 New replacement Turbidity Meters. Old ones have become obsolete.