

Tarentum Water Plant March 2021 Report

Amount of water processed.....31.3 million gallons

Overtime hours.....8 hrs.

All March DEP reports and testing completed and submitted

Annual Water Consumption Report completed March 29

Maintenance performed not including daily routine testing, sampling, and maintenance:

All Monthly Sampling

T.E.C. repaired a pressure transducer for the backwash flow

Replaced supply lines to the pressure transducer for the backwash meter

T.I.M. calibrated both the Raw and Finished flow meters March 30