

## Tarentum Water Plant September 2021 Boro Report

Water Processed.....31.0mg

Overtime hrs.....53hrs

Maintenance performed not including daily routine testing, sampling,  
and maintenance

River dredging 50% completed

Replaced the Backwash Control Actuator

Repaired the Pump House generator

Cleaned #3 Raw Water Pump