

Tarentum Water Plant March 2022 Report

Since my request on 1-30-22 to have a leak detection company check our system for excessive water loss; several leaks have been repaired. We now are using a significantly lesser amount of water per day. (avg. loss has been down 200,000 to 300,000 gallons per day!) for the first quarter of 2022

Amount of water processed.....28.0 million gallons. Down 3 million gallons from March 2021

Overtime hours.....52 hrs.

All March DEP reports and testing completed and submitted

Annual Water Consumption Report completed March 29

Maintenance performed not including daily routine testing, sampling, and maintenance:

All Monthly Sampling

Schulteis Roofing replaced all of the rubber and drains. Waiting for coping to be finished.

T.I.M. calibrated both the Raw and Finished flow meters March 30