

## Tarentum Water Plant April 2022 Report

Amount of water processed.....24.8 million gallons. (Down 4.5mg from April 2021)

Overtime hours.....34 hrs.

All April DEP reports and testing completed and submitted

Maintenance performed not including daily routine testing, sampling, and maintenance:

Plant roof has been completed

Cleaned Basins 1 & 2

Pittsburgh Pump & Motor is repairing pump #1 for the pump house