

Tarentum Water Plant February 2019 Report

Amount of water processed.....30.5 million gallons

Overtime.....27 hrs.

All February DEP reports and testing completed

Maintenance performed not including daily routine testing, sampling and maintenance:

Cryptosporidium/E.coli sampling

Lighting upgrade is 90% complete

Annual FPPE 2 day (Filter Plant Performance Evaluation) by the DEP completed

Repaired the Backwash Control Valve

Hach Service on Turbidity Meters

Cummins service on both Emergency Generators

Replaced the pressure regulator on the CL17 Chlorine Analyzer