

## Tarentum Water Plant November 2019 Report

Amount of water processed.....26.9 million gallons

Overtime hours.....71 hours

All November DEP reports and testing completed and will be submitted by 12-10-19

Maintenance performed not including daily routine testing, sampling, and maintenance

Cryptosporidium/E.Coli sampling

Pumphouse transfer switch replaced

Propane tank for pumphouse emergency generator filled

Filter room computer software upgraded

Plant PLC battery backup replaced

Plant basins cleaned

Plant raw water sample line cleaned