

Tarentum Water Plant April 2020 Report

Amount of water processed.....26.5 million gallons

Overtime hours.....56 hrs.

All April DEP reports and testing completed and submitted

Charleen Miller-Scholl returned back to work 4-16-20

Maintenance performed not including daily routine testing, sampling, and maintenance:

Replaced desiccant in the air dryer

Cleaned Basins 1 & 2

Fluoride machine repairs

Replaced the Block Heater on Pump House Generator