

Tarentum Water Plant May 2020 Report

Amount of water processed.....28.16 million gallons

Overtime Hours.....48 hrs.

All May DEP sampling has been completed

Interviewed applicant for the plant operator position

Purchased new plant entrance door

Maintenance performed not including daily routine testing, sampling, and maintenance

Pump Motor replacement

Repaired Delpac Line

Repaired fluoride machine spout

Plant Generator Maintenance completed by Cummins

Installed a loaner TU5300 meter to sed out ours for repair