

## Tarentum Water Plant June 2020 Report

Amount of water processed.....26.6 million gallons

Overtime hours.....80hrs.

All June DEP reports and testing completed and submitted

Maintenance performed not including daily routine testing, sampling, and maintenance:

Completed a 10 year Water Consumption Report that was requested by Michael

Reinstalled the repaired TU5300 Turbidity Meter

Repaired the air compressor

Completed and submitted the CCR (Consumer Confidence Report)

SCADA System has been upgraded for compatibility with windows 10

Purchased and installed a new chemical feed pump to replace broken one  
\$1710.00

Purchased a new entry door. Old door is rusted out. Will be installed next month.  
\$1900.00