

## Tarentum Water Plant August 2020 Report

Amount of water processed.....30.9 million gallons

Overtime hours.....32hrs.

All August DEP reports and testing completed and submitted

Maintenance performed not including daily routine testing, sampling, and maintenance:

Installed an automatic gate sensor

Cleaned out Delpac lines and tank

Replaced lab sink faucet

Painted plant doors

Repacked #1 distribution pump and #1 raw water pumps