

Tarentum Water Plant July 2021 Report

Amount of water processed.....30.9mg

Overtime Hours.....72 hrs.

All July reports and testing have been completed and submitted

Maintenance performed not including daily routine testing, sampling, and maintenance

Cleaned 2 river pumps

Replaced a compressor pump that went bad

Repaired an air valve for the #4 Effluent