



BOROUGH OF TARENTUM

318 Second Avenue
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818
Fax: 724-224-1821
www.tarentumboro.com

To: Tarentum Borough Mayor and Council

Tarentum Borough Water Report: June 2023

Water processed: 21.9mg

- Normal Monthly Operations.
- Replaced the Flash Mixer Motor.
- Repaired a water line that feeds the Fluoride and Potassium Permanganate Machines.
- Cleaned #3 Raw Water Pump at the Pump House.
- Cleaned out all low turbidity water lines.
- Consumer Confidence Report is completed.
- Cleaned out Turbidity Meter lines.
- 3 Rivers Diving came in to give an estimate for valve repairs and intake dredging.
- Chlorine Delivery.
- Cleaned Basement Area.