



BOROUGH OF TARENTUM

318 Second Avenue
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818
Fax: 724-224-1821
www.tarentumboro.com

To: Tarentum Borough Mayor and Council

Tarentum Borough Water Report: July 2023

Water processed: 22.7 MG.

- Normal Monthly Operations.
- Plant Meeting with Borough Manager.
- Purchased a new Potassium Permanganate Pump.
- Replaced all air filters.
- Estimate for river dredging.
- Replace mixer motor on the #1 mixer.
- Cleared vegetation away from pumphouse/fencing.
- Repairing the mixing motor drive unit.
- Kuntze chlorinator online. Replaced the Hach CL-17 Chlorinator.
-