



## BOROUGH OF TARENTUM

318 Second Avenue  
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818  
Fax: 724-224-1821  
www.tarentumboro.com

**To: Tarentum Borough Mayor and Council**

### **Tarentum Borough Electric Report: August 2023**

- 8/1: Work orders, CT Troubleshooting @ 806 E 5 Ave, 100 E 7 Ave, 151 W 4 Ave, 200 Boyd St
- 8/2: meeting regarding 3 phase metering/CT's, including policy and Code.
- 8/3: 3 phase metering @ 151 W 4th Ave, back brief email from meeting, troubleshot 1021 Summit St for voltage issues.
- 8/7: Cover up on 913 Lock St, 3 phase meter inspections @ 450, 460 Grantham St, 140 W 7 Ave
- 8/8: Inspected 323 E 11 Ave to install meter, Tree trimming E 11 Ave,
- 8/9: Hung HS and installed meter @ 323 E 11 Ave, 3 phase meter inspection @ 151 W 4 Ave
- 8/10: pulled meters from 204,427 W 8 Ave, and 440 E 7 Ave, meeting with chuck about sensus metering, Replaced red light @ 7ave & Ross St
- 8/14: heated up 527 5th Ave without metering, Ordered FM2s CLs 320 and FMs 15s CLs 320 from sensus meters.
- 8/15: 3 phase service inspections @ 221 James Wolfe BLVD, 200 Ross St, Developed service for Grandview Phase II project.
- 8/16: Inspected 3 phase metering, Designing Grandview II Project
- 8/17: Work Orders, built 5pcs each: #2 & #4 Ext., Designing Grandview II Project
- 8/18: Meter change out @ 222 Main St, 537 E 3rd Ave, 3 phase meter inspection @ 110 2nd Ave.
- 8/21: Inspected HS @ 222/220 Main St, initiated bucket inspections, Cleaned office & Bathroom.
- 8/22: CT wiring @ 527 E 5 Ave, Inventory
- 8/23: built 6 pcs: 4/0 Transformer leads, pulled 2 meters @ 531 E 3rd Ave, Replaced a foreign meter w/ a Tarentum Sensus meter @ 405 Allegheny St
- 8/24: Inspected 3 phase meters CT/VT's @ trib total media, Work orders.
- 8/25: Troubleshot meter @ 528 E 8 Ave, Inspected 3 phase meters & CT's @ Rachel Carson hall
- 8/28: Refused Cutouts @ 144 W 4 Ave, Inspected 3 phase meters @ F-Squared
- 8/29: Tested meters, Installed Hardware for Banners @ McKee St & E 1st Ave, Inspected 3 phase metering @ Boro Office, Further Inspection @ 222 E 4th Ave.
- 8/30: Recovered Rubber @ 913 Lock St, E 6 & E 10 Ave and Bakerstown Rd Pole replacement Project Prep, Planned highland St outage & No parking @ 1021 Summit St
- 8/31: Outage @ highland St Transferred Secondary, Span guy, and Installed down Guy