



## **BOROUGH OF TARENTUM**

318 Second Avenue  
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818  
Fax: 724-224-1821  
www.tarentumboro.com

**To: Tarentum Borough Mayor and Council**

**Tarentum Borough Water Report: February 2024**

**Water processed: 23.6 MG.**

- Normal Monthly Operations.
- A metal framed barrier was installed around the manhole leading into the Clearwell per DEP request.
- Daily Cl<sub>2</sub> results documented and sent to the DEP via email.
- Continuing with Cl<sub>2</sub> sampling requested by the DEP.
- Daily backwash Cl<sub>2</sub> readings documented and sent to the DEP on schedule.
- Ongoing troubleshooting along with the DEP to find a solution to the loss of Cl<sub>2</sub> during the backwash process.
- Required PFAS sampling started.
- Gibson Thomas is working on upgrading the SCADA System
- Chlorine Analyzer location drawings complete
- Data readings chlorine on top of filters are now being logged in out to 2 decimal places instead of 1.
- Continue to record chlorine readings every 5 minutes during the backwash cycle until further notice.
- Beginning to install moats around chemical feed machines.
- Gibson-Thomas is working with Cambria Systems on the new SCADA System.
- Working with 3 Rivers Diving on quotes for Cleaning and Inspecting the Clearwell and dredging.
- Beginning to work on the Water Consumption Report Due by 3-31-24.