

**2023 ANNUAL DRINKING WATER QUALITY REPORT  
BOROUGH OF TARENTUM PWSID #5020055**

This report is to inform you about the quality of water that we deliver to you everyday. We are committed to providing you with the highest quality of water possible, and continue to improve the water treatment process.

*Este informe contiene informacion muy inortante sobre su aqua de beber. Traduzcalo o hable con alguien que lo entienda bien.* (This report contains very important information about your drinking water. Translate it, or speak with someone who understands it.)

If you have any questions about this report, or concerning your water utility, please contact: **Jeffrey A Adams, Plant Manager, Tarentum Water Plant (724) 224-9688**

We want you to be informed about your water supply. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the 2<sup>nd</sup> Tuesday of the month at 6:00 located at 318 2<sup>nd</sup> Avenue Tarentum.

Our water source is treated surface water from the Allegheny River. A boom has been installed across the beginning of the intake to help keep out any spills of contaminants that may occur upstream of our raw water source. In May 2016, we joined with our neighboring surface water system to form the lower Allegheny regional protection partnership, to coordinate efforts to protect our source water. The Assessment has found that our source is potentially most susceptible to: storm water and CSO runoff from developed areas adjacent to the river carrying multiple contaminants; accidental release of known or unknown contaminants from upstream industrial discharge; accidental discharge from ruptured pipelines upstream from the intake; or Cumulative release of petroleum and other pollutants from pleasure boating and barge traffic along the river and the potential for accidental spills. Overall, our source has little risk of significant contamination. Summary reports of the Assessment are available by writing to Tarentum Borough 318 2<sup>nd</sup> Avenue, Tarentum PA 15084 and will also be available on the PADEP website at [www.dep.state.pa.us](http://www.dep.state.pa.us) (keyword: "DEP source water"). Copies of the complete report are available for review at the PADEP Southwest Regional Office, Records Management Unit at 412-442-4000.

**Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).**

We routinely monitor for contaminants in your drinking water according to Federal and State laws. The following tables show the results of our monitoring for the period of January 1 to December 31, 2023. The State allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data is from prior years in accordance with the Safe Drinking Water Act. The date has been noted on the sampling results table.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it

dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

\*Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.

\*Inorganic contaminants, such as salts and metals, which can be naturally occurring or results from urban storm water run-off, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

\*Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water run-off, and residential uses.

\*Organic chemical contaminants, including synthetic volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can, also, come from gas station, urban storm water run-off, and septic systems.

\*Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA and DEP prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA and DEP regulations established limits for contaminants in bottled water, which must provide the same protection for public health. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

Elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Borough of Tarentum is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Dalapon sample was not taken in the fourth quarter. There were no health risks to our customers.

We are pleased to inform you that by our testing table, the table shows that your drinking water meets or exceeds all Federal and State requirements. In order to maintain a dependable water supply we sometimes need to make improvements that will benefit all of our customers. We at Tarentum Water Plant work around the clock to provide top quality water to every household. Please help us in protecting our water sources.

**Sampling results table on opposite side.**