



## **BOROUGH OF TARENTUM**

318 Second Avenue  
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818  
Fax: 724-224-1821  
[www.tarentumboro.com](http://www.tarentumboro.com)

**To: Tarentum Borough Mayor and Council**

**Tarentum Borough Water Report: August 2024**

**Water processed: 28.1 MG.**

- Normal Monthly Operations.
- Dredging began but was delayed due to river level
- Replaced the motor on the Carbon Machine
- Number 2 basin was cleaned
- Containment for the Potassium Permanganate Machine started
- Hail damage to the plant vehicle was repaired
- DEP Chlorine Study sampling is complete.
- A new backwash control Valve Actuator was ordered. To be installed 8-16-24
- DEP installed 2- Chlorine Analyzers into the water distribution system
- #2 Distribution Pump is repaired. To be installed 8-16-24