



BOROUGH OF TARENTUM

318 Second Avenue
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818
Fax: 724-224-1821
www.tarentumboro.com

To: Tarentum Borough Mayor and Council

Tarentum Borough Water Report: November 2024

Water processed: 24.4 MG.

- Normal Monthly Operations.
- 12mg of water processed
- Raw water pump Replaced (small lab sink pump)
- Cleaned lab area flooring
- Painted bathroom
- Additional housekeeping throughout the plant
- #1 filter inspection completed
- Moat around the Fluoride Feed Machine completed
- Intake dredging is completed
- Plant office is ready to be furnished