



BOROUGH OF TARENTUM

318 Second Avenue
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818
Fax: 724-224-1821
www.tarentumboro.com

To: Tarentum Borough Mayor and Council

Tarentum Borough Electric Report: February 2025

- 2/3: Planned outage @ Main St, cut pole down to be pulled @ 210 2nd Ave,
- 2/4: Made two 1/0 triplex EXT., built outage summary for 601 E 2nd Ave, remarked 1-call positions for pole replacement projects, built 3EA 4/0 transformer leads.
- 2/5: Replaced cutouts 354, 235 W 8 Ave, investigated power Stone & Company.
- 2/6: Made 1 call for an upcoming pole replacement project and replaced the cutout @ 301 E 9 Ave. Deleted the defective meter from RNI.
- 2/7: Investigated meters @ 1123 Park and 604 Lock St for Errors. Reconnect 45 E 6th Ave.
- 2/10: Combed SA for bad meters, changed out meters @ 925 Porter St, 233 W 9 Ave, 101 W 7 Ave, pole replacement prep.
- 2/11: Combed SA for bad meters, changed meters @ 1st&Ross St, 619 E 3rd Ave, 114 2nd Ave, 201 Allegheny St, 425 2nd Ave.
- 2/12: Trimmed trees @ 191 E 10 Ave & 150 E 10 Ave, Editing and adding into NJUNS, pulled rubber from line @ 1125 Highland St, & 608 E 8 Ave, Cut and attached service to Pole @ 641 E 9th Ave, Secured pole to new pole @ Trib.
- 2/13: Cut and attached service to Pole 641 E 9th Ave, Meeting directed towards new Grecco service installation.
- 2/14: Combed SA, sharpened knives, pole replacement prep, Work orders.
- 2/17: Changed meters @ 314 W 6 Ave, 205 Conroy Way, inspected meters @ 233 W 9th Ave, 1123 Park St, attempted to locate meter @ 604 Lock St, Adjusted pole replacement project.
- 2/18: Work Orders, inspected meter & house drop @ 222 James Wolfe St., combed SA for troubled meters.
- 2/19: Prepped for pole replacement, combed SA and RNI for bad meters.
- 2/20: NJUNS training, combed SA for bad meters, changed out meter @ 920 Porter St & 535 E 9 Ave APT D.
- 2/21: Prepped for pole replacement, combed SA and RNI for bad meters, Cleaned garage.
- 2/24: Work Orders, Disconnect demo 505 5th Ave, pole inspection for pole replacement 5th Ave.
- 2/25: Dis/Reconnect @ 1005 Lawton St, pole inspections.
- 2/26: replaced cutout 357 W 8 Ave, Combed SA for bad meters.
- 2/27: Installed a new section of primary due to a car accident @ 211 Boyd St. combed RNI for alerts on meters, deleted 5 meters from RNI.
- 2/28: replaced cutout 324 W 10 Ave, got tires rotated on work truck, prepped for future pole replacements