



## **BOROUGH OF TARENTUM**

318 Second Avenue  
TARENTUM, PENNSYLVANIA 15084

Telephone: 724-224-1818  
Fax: 724-224-1821  
[www.tarentumboro.com](http://www.tarentumboro.com)

**To: Tarentum Borough Mayor and Council**

**Tarentum Borough Water Report: February 2025**

**Water processed: 25.7 MG.**

- Normal Monthly Operations.
- Files moved into office
- Began painting the chemical room floor
- New glassware received from Hach
- Preparing for the Annual Water Allocation Report
- Additional training for operators
- Paint chemical room floor
- Hach in with demo equipment
- Cleaned #1 and #2 sedimentation basins
- DEP visited for final inspection
- Gibson-Thomas to start pump permit application
- Previous quarterly average TTHM sample analysis came in at 72.25 ul, which is below the maximum 80 MCL.