



# BOROUGH OF TARENTUM

WATER DEPARTMENT  
618 E. 5<sup>TH</sup> AVENUE  
TARENTUM, PENNSYLVANIA 15084  
724.224.1818

## Monthly Report

Date Range: June 2025

### Water Plant:

Water processed: 26.67 MG.  
Average Chlorine Residual Levels: 1.75mg/l  
Average Tank Levels: 45 ft.

### Key items & work performed:

- **Preventive maintenance completed:**
  - N/A
- **Repairs performed or pending:**
  - N/A
- **Vendor visits or contractor work:**
  - N/A
- **Lab results received:**
  - N/A
- **DEP or regulatory communications:**
  - N/A
- **Safety issues or incidents:**
  - Chemical handling refresher training with employees
- **Status updates on ongoing projects**
  - TNT Welding completed repairs at the pumphouse
- **Budget or procurement needs**
  - N/A
- **Engineering/vendor coordination**
  - Delpac and Chlorine delivery received
  - Delay on Gibson Thomas requesting chemical injection permit.
- **Plant concerns or risks**
  - Pumps
  - Start up and Shut down checklist to be implemented on 6-20-25
- **Items needing Borough attention**
  - N/A
- **Other:**
  - Painting floors
  - Grass cut
  - MS4 outflow inspection and sampling at Bull Creek and 4<sup>th</sup> Ave

### Distribution:

Emergency Water Breaks: 0  
Water Breaks: 1  
Average Chlorine Residual Levels: .75 mg/l

### Key items & work performed:

- **Preventive maintenance completed:**
  - 12 MXU's ordered
- **Repairs performed or pending:**
  - N/A
- **Vendor visits or contractor work:**
  - N/A
- **DEP or regulatory communications:**
  - DEP is requiring the Borough to reissue the PN for not having it on the correct form and missing some language.
- **Safety issues or incidents:**
  - MS4 outflow inspection and sampling at Bull Creek and 4<sup>th</sup> Ave.
- **Status updates on ongoing projects**
  - Preparing for automatic flushers
- **Budget or procurement needs**
  - Used and replaced several items for W. 11<sup>th</sup> break.
- **Engineering/vendor coordination**
  - Discussion with engineers about a permit for potassium permanganate
- **Distribution concerns or risks**
  - TTHM levels
- **Items needing Borough attention**
  - N/A
- **Hydrant work or flushing:**
  - Cleaning out curb boxes
- **Other:**
  - N/A