

BOROUGH OF TARENTUM

WATER DEPARTMENT $618 \text{ E. } 5^{\text{TH}} \text{ AVENUE}$ TARENTUM, PENNSYLVANIA 15084 724.224.1818

Monthly Report

Date Range: July 2025

Water Plant:

Water processed: 29.7 MG.

Average Chlorine Residual Levels: 1.15 mg/l

Average Tank Levels: 45 ft.

Key items & work performed:

Preventive maintenance completed:

o Working on Pot. Perm. machine

o Delpac line repair

Repairs performed or pending:

o Delpac line cleaning

Vendor visits or contractor work:

o N/A

Lab results received:

o N/A

DEP or regulatory communications:

 CCR Completed and delivered 6-31-25

o CCR Cert. sent to DEP needs resent

Safety issues or incidents:

N/A

Status updates on ongoing projects

Waiting on permits from the DEP

Budget or procurement needs

o N/A

Engineering/vendor coordination

o Gibson/Thomas working on permits

Plant concerns or risks

o Pumps

Computer issues

 Feed pump for Fluoride needs replaced

Items needing Borough attention

 $\circ \quad N/A$

Other:

o Grass cut

New record sheets added to the computer

o New employee (Sam) started 7-7-

2.5

o T.Rapp retired 7-19-2025

Distribution:

Emergency Water Breaks: 1

Water Breaks: 2

Average Chlorine Residual Levels: .70 mg/l

Key items & work performed:

Preventive maintenance completed:

Valve checkin

o Replaced hydrant on E11th

Ave and valve #384

Repairs performed or pending:

o 4" water break at Bridge and Ekas

 \circ 8th and Dickey fixed broken hydrant valve

Vendor visits or contractor work:

o N/A

DEP or regulatory communications:

o N/A

Safety issues or incidents:

o N/A

Status updates on ongoing projects

• Preparing for automatic flushers

Budget or procurement needs

o N/A

Engineering/vendor coordination

o Discussion with engineers about a permit for potassium permanganate

Distribution concerns or risks

o TTHM levels

■ Items needing Borough attention

o N/A

Hydrant work or flushing:

Cleaning out curb boxes

Other:

o Sewage shutoffs

Non-payment shutoffs

o MXU maintenance