



BOROUGH OF TARENTUM

WATER DEPARTMENT
618 E. 5TH AVENUE
TARENTUM, PENNSYLVANIA 15084
724.224.1818

Monthly Report

August 2025

Water Plant:

Average Water processed: 14.95 MG.
Average Chlorine Residual Levels: 1.5 mg/l
Average Tank Levels: 45 ft.

Key items & work performed:

- **Preventive maintenance completed:**
 - Pot. Perm. Liquid level controller replaced
 - Light bulb replacement
 - LMI pump for fluoride replaced
 - Cummins performed PM on emergency generators
 - Start organizing computer/Data wiring in lab area
 - Floor painting in lab area
- **Repairs performed or pending:**
 - #3 filter inlet air valve to be replaced
 - Chlorine regulator maintenance
 - Basin valve needs replaced
- **Vendor visits or contractor work:**
 - Carl from Citgo visited
- **Lab results received:**
 - TTHM and Haa5 results back from the lab
- **DEP or regulatory communications:**
 - Weekly sheets and CCR Cert. form sent
 - Talked to Rhiannon about possible violation (CCR Delivery)
- **Safety issues or incidents:**
 - N/A
- **Status updates on ongoing projects**
 - Waiting on permits from the DEP
 - Waiting on a basin valve to be replaced
- **Budget or procurement needs**
 - N/A
- **Engineering/vendor coordination**
 - Gibson/Thomas working on permits
- **Plant concerns or risks**
 - Pumps
 - Computer issues
 - Feed pump for Fluoride needs replaced
- **Items needing Borough attention**
 - N/A
- **Other:**
 - Grass cut

Distribution:

Emergency Water Breaks: 4
Water Breaks: 3
Average Chlorine Residual Levels: .85 mg/l

Key items & work performed:

- **Preventive maintenance completed:**
 - Checking valves
 - Moving noise readers on schedule
- **Repairs performed or pending:**
 - Main break at 191 Davidson
 - Main break at Bridge st.
 - Main break at Park Ave.
 - Replace 4 MXU's do to no reads
- **Vendor visits or contractor work:**
 - N/A
- **DEP or regulatory communications:**
 - N/A
- **Safety issues or incidents:**
 - N/A
- **Status updates on ongoing projects**
 - Automatic flushers (4) online
 - Moved noise loggers
- **Budget or procurement needs**
 - N/A
- **Engineering/vendor coordination**
 - N/A
- **Distribution concerns or risks**
 - TTHM levels
- **Items needing Borough attention**
 - N/A
- **Hydrant work or flushing:**
 - Cleaning out curb boxes
- **Other:**
 - Sewage shutoffs
 - Non payment shutoffs

- New records sheets added into computer