



BOROUGH OF TARENTUM

WATER DEPARTMENT
618 E. 5TH AVENUE
TARENTUM, PENNSYLVANIA 15084
724.224.1818

Monthly Report

September 2025

Water Plant:

Water processed: 15.2 MG.
Average Chlorine Residual Levels: 1.65 mg/l
Average Tank Levels: 45.5 ft.

Key items & work performed:

- **Preventive maintenance completed:**
 - Continue organizing computer/Data wiring in lab area
 - Floor painting in lab area
 - Replaced #3 Influent Air solenoid valve
 - Floor painting in Drive area
- **Repairs performed or pending:**
 - Chlorine regulator maintenance
 - Basin valve needs replaced
- **Vendor visits or contractor work:**
 - N/A
- **Lab results received:**
 - N/A
- **DEP or regulatory communications:**
 - Resent AOR to DEP
 - Weekly sheets and CCR Cert. form sent
 - Talked to Rhiannon about possible violation (Chlorine Results for sample location 701, 703, 705)
- **Safety issues or incidents:**
 - N/A
- **Status updates on ongoing projects**
 - DEP Permits in for Pot. Perm. And the new tank
 - Waiting on Chlorine Alarm and sensors
 - Waiting on a basin valve to be replaced
- **Budget or procurement needs**
 - Beginning wish list for 2026
- **Engineering/vendor coordination**
 - Gibson/Thomas working on permits
- **Plant concerns or risks**
 - Pumps
 - Computer issues
- **Items needing Borough attention**
 - N/A
- **Other:**
 - Grass cut
 - Quarterly Calibrations for 4th quarter
 - Alarm testing for 4th Quarter

Distribution:

Emergency Water Breaks: 0
Water Breaks: 0
Average Chlorine Residual Levels: .75 mg/l

Key items & work performed:

- **Preventive maintenance completed:**
 - Checking valves
 - Moving noise readers on schedule
 - Checked Hydrant Flushers
- **Repairs performed or pending:**
 - Replaced leaking water meter 318 W8th
 - Replace a MXU do to no reads
- **Vendor visits or contractor work:**
 - N/A
- **DEP or regulatory communications:**
 - N/A
- **Safety issues or incidents:**
 - N/A
- **Status updates on ongoing projects**
 - Automatic flushers (4) online
 - Moved noise loggers
- **Budget or procurement needs**
 - N/A
- **Engineering/vendor coordination**
 - N/A
- **Distribution concerns or risks**
 - TTHM levels
- **Items needing Borough attention**
 - N/A
- **Hydrant work or flushing:**
 - Cleaning out curb boxes
- **Other:**
 - Sewage shutoffs
 - Shutoffs
 - Winterized spray park
 - Dug up service line at Porter St.

