



BOROUGH OF TARENTUM

REDCAT ELECTRIC DEPARTMENT
318 E. SECOND AVENUE
TARENTUM, PENNSYLVANIA 15084
724.224.181

Bi-Monthly Report

Date Range: 10/1-15/25

Emergency Outages:

Planned Outages: See Sewage plant project information

Overtime Hours: 4

System Operations

- Outages reported and cause (if known)
 - See Sewage plant project information
- Restoration times and response summary
 - See Sewage plant project information
- System inspections completed (poles, transformers, lines)
 - SP project prep
- Smart meter data/alerts reviewed
 - Attempt to review alerts daily

Maintenance & Repairs

- Preventive maintenance completed
 - See Sewage plant project information
 - Reconnect 225 W 7 Ave
 - Inspection 326 W 8 Ave
 - NJUNS work referring to previous projects
 - Reconnect 204 W 12 Ave
- Transformers or fuses replaced
 - Swapped a 50 KVA for a 37.5 KVA – Coe St
 - Swapped a 25 KVA for a 50 KVA- Porter St
- Bucket truck use or repairs
 - N/A
- Line clearance or tree trimming work
 -

Projects & Capital Improvements

- New services connected or meters replaced
 -
- Budget or procurement needs
 - ...

Regulatory & Safety

- Incident reports or near-misses
 - None
- PPE inventory or equipment needs
 - ...

Other Items

- Community complaints addressed
 - N/A
- Coordination with other departments or utilities
 - See Sewage plant project information
- Future planning or concerns
 - More to follow
- Other work or items:
- **MORE TO FOLLOW**