



# BOROUGH OF TARENTUM

WATER DEPARTMENT  
618 E. 5<sup>TH</sup> AVENUE  
TARENTUM, PENNSYLVANIA 15084  
724.224.1818

## Monthly Report

January 2026

### Water Plant:

Water processed: 28.54 MG.

Average Chlorine Residual Levels: 1.2 mg/l

Average Tank Levels: 45 ft.

### Key items & work performed:

- **Preventive maintenance completed:**
  - Cummins generator coming on 2-16-2026 to inspect and service generators
- **Repairs performed or pending:**
  - Furgeson heating installed the 2 new space heaters, installed all new digital thermostats aswell
- **Vendor visits or contractor work:**
  - HACH was here to service all our turbidity meters, Ph probes in re mix tank and clearwell. All are good and working properly.
  - Total Equipment is currently working on the Fluoride Machine gearbox.
- **Lab results received:**
  - General Monthly Testing
  - Total Coliform and PFAS samples were obtained so far, all samples are good, no violations.
- **DEP or regulatory communications:**
  - N/A
- **Safety issues or incidents:**
  - N/A
- **Status updates on ongoing projects**
  - N/A
- **Budget or procurement needs**
  - We have received 4 backup LMI chemical feed pumps and rebuild kits, so now we have backup pumps for each chemical for water treatment.
  - Del-Pac coagulant
- **Engineering/vendor coordination**
  - Tank mixer and potassium permanganate bid opening on 1-20-2026
- **Plant concerns or risks**
  - Pumps
  - Motors
- **Items needing Borough attention**
  - N/A
- **Other:**
  - A new monitor for cameras was installed and is now operating properly.

### Distribution:

Emergency Water Breaks: 2 (Negley; West 11<sup>th</sup>)

Water Breaks: 0

Average Chlorine Residual Levels: .65 mg/l

### Key items & work performed:

- **Preventive maintenance completed:**
  - N/A
- **Repairs performed or pending:**
  - Negley
  - West 11<sup>th</sup>
- **Vendor visits or contractor work:**
  - N/A
- **DEP or regulatory communications:**
  - N/A
- **Safety issues or incidents:**
  - PA 1 calls
- **Status updates on ongoing projects**
  - Permanent automatic flushers (4) have arrived. Waiting for warmer weather for installation
- **Budget or procurement needs**
  - N/A
- **Engineering/vendor coordination**
  - N/A
- **Distribution concerns or risks**
  - TTHM levels
- **Items needing Borough attention**
  - N/A
- **Hydrant work or flushing:**
  - Feb 16th flushing prior to TTHM level sampling on 17th.
- **Other:**
  - Regular turn on and turn off requests.
  - Sewage shutoffs.
  - Checking on or replacing several frozen meters.

- Charlie and Sam attended a Chlorine Math and Chlorination class.
- Fire extinguisher tested
- Ad posted for Water Systems Manager job

○

○