



BOROUGH OF TARENTUM

WATER DEPARTMENT
618 E. 5TH AVENUE
TARENTUM, PENNSYLVANIA 15084
724.224.1818

Monthly Report

January 2026

Water Plant:

Water processed: 30.9 MG
Average Chlorine Residual Levels: 1.2 mg/l
Average Tank Levels: 45 ft.

Key items & work performed:

- **Preventive maintenance completed:**
 - Cummins generator coming on 2-16-2026 to inspect and service generators
- **Repairs performed or pending:**
 - Furgeson heating installed the 2 new space heaters, installed all new digital thermostats as well
 - Backwash pump 1
- **Vendor visits or contractor work:**
 - Backwash pump
 - Air compressor replacement
- **Lab results received:**
 - General Monthly Testing
 - Total Coliform and PFAS
- **DEP or regulatory communications:**
 - We will need to reissue the tier 2 notification over a rounding difference
- **Safety issues or incidents:**
 - N/A
- **Status updates on ongoing projects**
 - N/A
- **Budget or procurement needs**
 - We have received 4 back up LMI chemical feed pumps and rebuild kits so now we have back up pumps for each chemical for water treatment,
 - Del-Pac coagulant
- **Engineering/vendor coordination**
 - Tank mixer and potassium permanganate installation
- **Plant concerns or risks**
 - Pumps
 - Motor
- **Items needing Borough attention**
 - N/A
- **Other:**
 - Fire extinguishers tested

Distribution:

Emergency Water Breaks: 4
Water System Repairs: 2
Average Chlorine Residual Levels: .65 mg/l

Key items & work performed:

- **Preventive maintenance completed:**
 - N/A
- **Repairs performed or pending:**
 - Water Breaks: East 8th/Fenzel
 - 229 West 9th –
 - Hill Street –
 - Conwell/Davidson –
 - 337 West 9th
 - Cedar Street
- **Vendor visits or contractor work:**
 - Leak ID called in for 4.5 hours to help find leak
- **DEP or regulatory communications:**
 - N/A
- **Safety issues or incidents:**
 - PA 1 calls
- **Status updates on ongoing projects**
 - Permanent automatic flushers (4) have arrived. Waiting for warmer weather for installation
- **Budget or procurement needs**
 - N/A
- **Engineering/vendor coordination**
 - N/A
- **Distribution concerns or risks**
 - TTHM levels
- **Items needing Borough attention**
 - N/A
- **Hydrant work or flushing:**
 - Feb 16th flushing prior to TTHM level sampling on 17th.
 - Hydrant on Davidson and Conwell off due to valve issue
- **Other:**
 - Sewage shutoffs.
 - Checking on or replacing several frozen meters.

