



BOROUGH OF TARENTUM

WATER DEPARTMENT
618 E. 5TH AVENUE
TARENTUM, PENNSYLVANIA 15084
724.224.1818

Monthly Report

April 2026

Water Plant:

Water processed: 29.02 MG
Average Chlorine Residual Levels: 1.2 mg/l
Average Tank Levels: 45 ft.

Key items & work performed:

- **Preventive maintenance completed:**
 - Regular maintenance duties
- **Repairs performed or pending:**
 - Ventilation fans on our Distribution Drives #1, #2. And #3 river pump drive.
- **Vendor visits or contractor work:**
 - Quarterly calibrations and maintenance on our monitoring and testing equipment.
 - Chlorine level and new scales were installed and programmed into our SCADA system for the operators to monitor the chlorine level in the cylinders.
- **Lab results received:**
 - General Monthly Testing
 - Total Coliform and PFAS
- **DEP or regulatory communications:**
- **Safety issues or incidents:**
 - N/A
- **Status updates on ongoing projects**
 - N/A
- **Budget or procurement needs**
 - We have received 4 backup LMI chemical feed pumps and rebuild kits, so now we have backup pumps for each chemical for water treatment.
 - Del-Pac coagulant
- **Engineering/vendor coordination**
 - Meeting with engineering about tank mixer and potassium permanganate installation
- **Plant concerns or risks**
 - Pumps
 - Motor
- **Items needing Borough attention**
 - N/A
- **Other:**
 - 12 cylinders of chlorine

Distribution:

Emergency Water Breaks: 0
Water System Repairs: 2
Average Chlorine Residual Levels: .65 mg/l

Key items & work performed:

- **Preventive maintenance completed:**
 - N/A
- **Repairs performed or pending:**
 - Walter Ave. valve replacement
- **Vendor visits or contractor work:**
 - N/A
- **DEP or regulatory communications:**
 - N/A
- **Safety issues or incidents:**
 - PA 1 calls
- **Status updates on ongoing projects**
 - Starting installation of permanent flushers
 - Planning for new smart pressure meter installation in Q2
- **Budget or procurement needs**
 - N/A
- **Engineering/vendor coordination**
 - N/A
- **Distribution concerns or risks**
 - TTHM levels
- **Items needing Borough attention**
 - N/A
- **Hydrant work or flushing:**
 - May 11 -22nd is the spring hydrant flushing
 - West 4th emergency hydrant repair
- **Other:**
 - Sewage shutoffs.
 - Rotation of noise loggers
 - Regular work, including turning on and off and minor repairs

