



# BOROUGH OF TARENTUM

REDCAT ELECTRIC DEPARTMENT  
318 E. SECOND AVENUE  
TARENTUM, PENNSYLVANIA 15084  
724.224.181

## Monthly Report

April 2026

**Emergency Outages:** 6

**Planned Outages:** N/A

**Overtime Hours:** 52.5

### System Operations

- Outages reported and cause (if known)
  - Replaced broken crossarm
  - Lost 2 phases @ W 6<sup>th</sup> Ave & Center St
  - Blinking lights across 5 house W 9<sup>th</sup> Ave & replaced transformer, leads, connections
  - WPP voltage surge blew traffic light fuses
  - Downed pole W 12 Ave
  - Blowin cutout @ W 9<sup>th</sup> Ave
  - Refused cutouts due to storms
- Restoration times and response summary
  - 2.5 hrs to 5 hrs
- System inspections completed (poles, transformers, lines)
  - SCCR conducted for E 5<sup>th</sup> Ave business
  - Pole inspections conducted
- Smart meter data/alerts reviewed
  - Reviewed meter read sheet

### Maintenance & Repairs

- Preventive maintenance completed
  - Demoed 4<sup>th</sup> & worth st old pole
  - Dedicated printer circuit for boro garage
  - Reconnect W 8<sup>th</sup> Ave
  - Replaced broken cutout & arrester on W 7<sup>th</sup> Ave
  - Finished crossarm transfer on W 7<sup>th</sup> Ave
  - Started Out-building service at boro garage
  - Installed timer for Boro office
  - Trimmed trees/raised triplex on Davidson St
- Transformers or fuses replaced
  - N/A
- Bucket truck use or repairs
  - N/A
- Line clearance or tree trimming work
  - N/A

### Projects & Capital Improvements

- New services connected or meters replaced
  - Replaced meters @ Creek st, W 8<sup>th</sup> Ave, W 6 Ave, E 8<sup>th</sup> Ave,
- Budget or procurement needs
  - ...

### Regulatory & Safety

- Incident reports or near-misses
  - None
- PPE inventory or equipment needs
  - ...

### Other Items

- Community complaints addressed
  - N/A
- Coordination with other departments or utilities
  - ...
- Future planning or concerns
  - More to follow
- Other work or items:
  - N/A

