



BOROUGH OF TARENTUM

WATER DEPARTMENT
618 E. 5TH AVENUE
TARENTUM, PENNSYLVANIA 15084
724.224.1818

Monthly Report

July 2026

Water Plant:

Water processed: 31.185 MG (July 1–31)

Average Chlorine Residual Levels: [pending] mg/l

Average Tank Levels: [pending] ft.

Key items & work performed:

- **Preventive maintenance completed:**
 - Plant maintenance performed daily by operators, along with monthly calibrations and safety inspections
- **Repairs performed or pending:**
 - Basin room door and lab door opener replaced for proper operation
 - Backwash Pump #2 nearing completion; ready for installation once manpower is available
 - Distribution Pump #2 installed; will be used in the near future
 - #3 basin effluent valve repair in progress — Three Rivers Diving on-site
- **Vendor visits or contractor work:**
 - Three Rivers Diving on-site to repair the #3 basin effluent valve
 - Total Equipment: scheduling installation of the permanently mounted exterior ladder with fall-protection cage (chlorine room)
- **Lab results received:**
 - TC sampling scheduled for 8/4
- **DEP or regulatory communications:**
 - Charlie is now able to complete DEP DWELR and Chapter 110 reporting and is assisting with monthly reporting
- **Safety issues or incidents:**
 - Total Equipment to install a permanently mounted exterior ladder with fall-protection cage on the chlorine room for safe access to the plant roof
- **Status updates on ongoing projects:**
 - Potassium permanganate system at the pump house is up and running; proper operating procedures still in development
 - Distribution Pump #2 installed; to be placed in service in the near future
 - Backwash Pump #2 nearing completion; ready for installation once manpower is available
- **Budget or procurement needs:**
 - N/A
- **Engineering/vendor coordination:**

Distribution:

Emergency Water Breaks: 0

Water System Repairs: 4

Average Chlorine Residual Levels: [pending] mg/l

Key items & work performed:

- **Preventive maintenance completed:**
 - Moved noise readers
 - PA One Call locate requests submitted
- **Repairs performed or pending:**
 - Water turn-on — 5 10th Ave. (7/16)
 - 636 2nd Ave. (7/17): No-read blue tag; replaced wire
 - 1422 Bakerstown Rd. (7/17): Checked manhole behind property at homeowner request; manhole clear
 - 248 W 9th Ave. (7/20): Water turn-on; new meter set for one unit — a second service line is needed to set an additional meter
 - Water turn-on — 100 Boyd St. (7/21)
 - 800 Ormond (7/22): Blue tag for high usage; resident contacted the office
 - E 6th Ave. and W 4th Ave. hydrant (7/22): Vac truck for sinkhole
 - Water turn-offs — 800 Mill St. and 12 10th Ave. (7/23): non-payment
 - 405 E 9th Ave. (7/23): Installed smart meter and MXU
 - W 4th Ave. (7/24): Replaced hydrant. Materials: 1 ea. 6" Mega lug; 1 ea. Kennedy hydrant
 - 439 E 7th Ave. (7/27): Water turn-on; replaced leaking meter
 - Water turn-off — 600 E 8th Ave. (7/28): leak inside house
 - 412 E 4th (7/29): Water turn-on; sewage shut-off
 - 200 block of 7th Ave. (7/30): PA One Call for water leak
 - 800 Mill St. (7/31): Water turn-on. 411 E 7th Ave.: water turn-off — interior access needed to locate where the water line exits the house; curb box not found outside
- **Vendor visits or contractor work:**
 - N/A
- **DEP or regulatory communications:**
 - N/A
- **Safety issues or incidents:**

- Three Rivers Diving: #3 basin effluent valve repair
 - Total Equipment: exterior ladder installation on the chlorine room
 - **Plant concerns or risks:**
 - N/A
 - **Items needing Borough attention:**
 - N/A
 - **Other:**
 - N/A
- N/A
 - **Status updates on ongoing projects:**
 - Installed smart meters and MXUs (7/27–7/31): 313 Bridge St., 1107 Constitution St., 121 W 7th Ave., 323 E 11th Ave., 407 E 6th Ave., 1037 Summit St., 132 W 12th Ave., 301 Corbet St., 419 2nd Ave., 1120 Stewart St., 640 E 10th Ave., 300 W 11th Ave.
 - **Budget or procurement needs:**
 - N/A
 - **Engineering/vendor coordination:**
 - N/A
 - **Distribution concerns or risks:**
 - N/A
 - **Items needing Borough attention:**
 - N/A
 - **Hydrant work or flushing:**
 - Replaced W 4th Ave. hydrant (7/24)
 - **Other:**
 - Call-out at 6:20 PM from the water plant (7/31): band shelter urinal running; valve shut off — flusher needs repair